



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services
Asansol Fire Station, G.T. Road, P.O.:-Asansol,
P.S.:-Asansol(South), Pin :- 713301

Memo no.:FSR/0125186230300394

Date: 31-01-2024

From:

Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services

To: VIDYA SAGAR TEACHER TRAINING COLLEGE (KALNAR MUKH)

BHABANANDAPUR, L.R PLOT NO-1227,1228, 1258,1259, L.R KH. NO-1316, MOUZA-BHABANANDAPUR, J.L NO.-155 UNDER ANUKHAL GRAM PANCHAYET. P.S-KALNA, DIST-PURBA BARDHAMAN.

Sub: Fire Safety Certificate for the occupancy of an existing Construction G+3 storied Building under group of Educational Building in favour of VIDYA SAGAR TEACHER TRAINING COLLEGE (KALNAR MUKH) at the premises BHABANANDAPUR, L.R PLOT NO-1227,1228, 1258,1259, L.R KH. NO-1316, MOUZA-BHABANANDAPUR, J.L NO.-155 UNDER ANUKHAL GRAM PANCHAYET. P.S-KALNA, DIST-PURBA BARDHAMAN.

This is in reference to your application no. 0125189240300011 dated 22-01-2024 regarding the Fire Safety Certificate for the occupancy of an existing Construction G+3 storied Building under group of Educational Building in favour of VIDYA SAGAR TEACHER TRAINING COLLEGE (KALNAR MUKH) at the premises BHABANANDAPUR, L.R PLOT NO-1227,1228, 1258,1259, L.R KH. NO-1316, MOUZA-BHABANANDAPUR, J.L NO.-155 UNDER ANUKHAL GRAM PANCHAYET. P.S-KALNA, DIST-PURBA BARDHAMAN.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a closed circuit T.V. system will have to be installed which observes entire of the buildings.

6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.
7. Good hose keeping of the all building shall be provided .
8. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
9. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. Transformer and DG set shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
11. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
12. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
13. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
14. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
15. Periodical flashing of water in the Hydrants shall be made to maintain the efficiency working performance of above mention system.
16. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
17. Fire license to be obtained from the License Department of W.B.F&E.S for storing combustible materials.
18. All the electrical cable should be paint by fire stop paint to check the spread of fire.
19. If anything happens for improper life safety measure in the building within this period then authority will be responsible for that.
20. The fire safety certificate is valid for three years from the date of issue, and has to be renewed after Three years certifying about the satisfactory services, performance of all the Life And Fire Safety arrangements installations of the building.

Signature valid

Digitally Signed:
Name: SHUVRANSHU MAZUMDER
Date: 31-Jan-2024 10:03
Reason: Approved
Location: West Bengal

Divisional Fire Officer (Member Convenor),
Paschim Bardhaman
West Bengal Fire & Emergency Services